

DATE: April 23, 2024


TO: Plan Holders

SUBJECT: PRE-BID SUBMITTED QUESTIONS AND RESPONSES

HL-0004 - 17th Street Extension

City of Hickory

(Bids to be opened and read Thursday, May 9, 2024 at 2:00 p.m.)



The following are pre-bid questions that were submitted by various bidders (up to 04/22/24). Responses follow and are denoted in **red**.

1. In the (*pre-bid*) meeting yesterday (04/17/24), it was brought up that there will be NO tree cutting allowed from 4/1 through 10/15, and I see it in the spec's SPI G18C. Is this to mean that there will be no clearing during this period or does this reference that there is no trimming or limbing during that period?

No cutting down or trimming of trees will be allowed during this period for any tree over 3" dbh (diameter at breast height). Clearing areas with only trees less than 3" dbh may occur at any time.

2. Is there a Geotech report on this project? If not, is there a rock clause?

The Geotech Inventory is being provided as part of this addenda. No rock clause will be included for this project.